REQUEST FOR INFORMATION (RFI) VA-251-12-B-0122

| PROJECT NUMBER: | 515-12-109 | | that before submitting questions or requests |
|----------------------------------|---|--|---|
| PROJECT TITLE: PROJECT LOCATION: | Medical Gas System Upgrade Department of Veterans Affairs Battle Creek VA Medical Center 5500 Armstrong Road Battle Creek, MI 49037 | specifications, When submitti requires contra and/or solicitat reference to th submitted. No answered by th are met. Failu | n that you thoroughly read the solicitation, drawings and other pertinent documents. In guestions on this project the Government actors to specifically identify the specification action section(s) or drawing number(s) in equestion or request for clarification question or request for clarification will be the Government unless the above requirements are to comply may prevent the Government and in a timely manner. |
| SUBMITTED BY: | N/A | City/State: | N/A |

| SUBMITTED BY: | N/A | City/State: | N/A |
|---------------|-----|-------------|-----|
| PHONE NO.: | N/A | | |

TO:

Sonny Earls, Contract Specialist Department of Veterans Affairs Aleda E. Lutz VA Medical Center 1500 Weiss St. Saginaw, MI 48602

Email: Sonny.Earls@va.gov

| RFI NO.: 2 | DATE: 6/4/12 | SPEC/DWG. REFERENCE: |
|------------------|--------------|----------------------|
| REPLY NEEDED BY: | | |

INFORMATION NEEDED:

- 1. During the site visit we noticed what appeared to be NFPA 99 deficiencies in the medical gas systems outside the scope of work of this project. Will the VA sign-off on the medical gas certification if there are NFPA 99 discrepancies noted outside of this project?
- 2. Will the VA wiring guidelines be in effect which require all wiring, high voltage and low voltage, to be placed in conduit regardless of location?
- 3. For the purposes of estimating, can proposers assume the existing underground conduit has sufficient space to pull new pairs? The VA needs to consider the empty space in the conduit as well as the existing cables, i.e. fire alarm.
- 4. For the purposes of estimating, should proposers include a 1-day site investigation for medical gas NFPA 99 compliance and a 1-day design charrette to develop a master plan for future corrective work?

REPLY:

- Question is speculative and assumes non-compliance in areas outside the scope of work identified in the Statement of Bid Items. No response is required or offered. However, unforeseen or differing conditions affecting work identified in the Statement of Bid Items are addressed during construction as contract modification requests.
- 2. Yes, VA Guidelines will be in effect.
- 3. Yes, this assumption can be made.
- 4. No.

| REPLY FROM: | DATE: |
|----------------------------|----------|
| George A. Granger III, COR | 6-4-12 |
| ATTACHMENTS: | COPY TO: |
| | |